

Gemeinde Büchenbach

integr. Entw.-Planung (IEP)

PROGNOSE-Q_m KA 60 l/s ohne Erw. RÜB KA

Element	hNa	Ab,a	pI	pII	pIII	fD	tf	NGm	d·I	QT,d	QT,max	QR,Tr	QM
	[mm]	[ha]	[%]	[%]	[%]	[-]	[min]	[-]	[m]	[l/s]	[l/s]	[l/s]	[l/s]
RB02	769.00	4.91	30.00	60.00	10.00	1.000	4.46	2.82	0.01887	0.71	1.54	0.00	68.00
RB01	769.00	9.01	30.00	60.00	10.00	1.000	8.43	2.39	0.00941	1.85	4.00	0.75	253.60
BB02	769.00	18.20	71.00	26.00	3.00	1.000	8.05	2.47	0.00795	3.22	6.96	2.84	55.00
BB_01	769.00	11.32	30.00	39.00	31.00	1.000	6.67	2.20	0.01097	3.48	6.88	3.87	35.00
VB04	769.00	55.18	43.62	44.39	11.98	1.000	21.50	2.52	0.00984	11.40	24.01	7.87	60.00
BB04	769.00	55.18	43.62	44.39	11.98	1.000	21.50	2.52	0.00984	11.40	24.01	7.87	60.00
KLA	769.00	55.18	43.62	44.39	11.98	1.000	22.50	2.52	0.00984	11.40	24.01	7.87	60.00

HINWEIS: Die hier ausgewiesenen Werte fuer dI sind kritisch zu hinterfragen, sofern Fließzeit- oder Nullsammler im System vorliegen